


# CONCENTRATED LOAD TEST

Lot No.	: 2010341	Test Date	: 2020-10-08
Panel sample	: G-E4N(10kN)	Temp./Hum.	: 21°C, 40%
Panel type	: Grating	Test speed	: 5mm/min
Dimension(mm)	: 600X600Xt50	Test standard	: CISCA
Test Point	: Center	Tested by	: DK You



## TEST RESULT

No.	SQUARE	WEIGHT	MAX. STR.	MAX STRE.	CON. LOAD	MAX. LOAD	DEFLECTION LOAD	
	【mm <sup>2</sup> 】	【Kg】	【mm】	【Kgf/mm <sup>2</sup> 】	【Kgf/2.0mm】	【Kgf】	【Kgf/1.0mm】	【Kgf/3.0mm】
C1	1963.5		7.594	1.527	1,343	2,998		
C2	1963.5		6.526	1.487	1,334	2,920		
C3	1963.5		6.354	1.534	1,322	3,012		

TEST CONFIRMED BY :

