


CONCENTRATED LOAD TEST

Lot No.	: 2010337	Test Date	: 2020-10-08
Panel sample	: P-E4N(10kN)	Temp./Hum.	: 21°C, 40%
Panel type	: Bperforated	Test speed	: 5mm/min
Dimension(mm)	: 600X600Xt50	Test standard	: CISCA
Test Point	: CENTER	Tested by	: DK You



TEST RESULT

No.	SQUARE	WEIGHT	MAX. STR.	MAX STRE.	CON. LOAD	MAX. LOAD	DEFLECTION LOAD	
	【mm ² 】	【Kg】	【mm】	【Kgf/mm ² 】	【Kgf/2.0mm】	【Kgf】	【Kgf/1.0mm】	【Kgf/3.0mm】
C1	1963.5		9.93	1.99	1,365	3,908		
C2	1963.5		11.091	2.052	1,310	4,030		
C3	1963.5		10.996	2.009	1,417	3,944		

TEST CONFIRMED BY :

